



## **GENERAL NOTES**

- A. ALL DIMENSIONS ARE FOR GENERAL ARRANGEMENT AND LOCATION ONLY - ACTUAL REQUIREMENTS AND DIMENSIONS SHOULD BE VERIFIED AND COORDINATED WITH EQUIPMENT, SHOPS DRAWING SUBMITTALS AND STRUCTURAL FRAMING
- B. ALL 'TOP OF' ELEVATIONS SHOWN ARE BASED FROM DATUM FINISH FLOOR ELEVATION 0'-0"
  C. ALL JOINTS IN METAL REVEALS AND EXPOSED TRIM ARE BUTT
- JOINT NO LAP JOINTS SEAL PRIOR TO PAINT FOR WEATHER TIGHT CONDITION D. SEE STRUCTURAL MECHANICAL PLUMBING AND ELECTRICAL
- D. SEE STRUCTURAL, MECHANICAL, PLUMBING AND ELECTRICAL DRAWINGS FOR ADDITIONAL EQUIPMENT/ITEMS AND ROOF PENETRATIONS NOT SHOWN ON ROOF PLAN
   E. ROOF DRAIN DOWN SPOUT LOCATIONS SHALL BE COORDINATED
- E. ROOF DRAIN DOWN SPOUL LOCATIONS SHALL BE COORDINATED WITH THE ARCHITECTURAL FLOOR PLAN AND THE PLUMBING PLAN FOR PROPER PLACEMENT
- F. CONTRACTOR TO VERIFY/COORDINATE DUCT, CURB, ROOF PENETRATION LOCATIONS
- G. SEE STRUCTURAL FRAMING PLAN FOR ROOF MEMBER
- LOCATIONS H. ALL AREAS OF THE ROOF SURFACE SHALL MAINTAIN A MINIMUM 1/4" PER FOOT SLOPE
- I. ROOFING CONTRACTOR SHALL FURNISH AND INSTALL ANY/ALL REGLETS
- J. LOCATION OF FLASHING AND COUNTER FLASHING ABOVE ROOF SURFACE IS TO BE INSTALLED IN COMPLIANCE WITH THE ROOFING MANUFACTURER'S REQUIREMENTS
- K. ALL ROOF MOUNTED EQUIPMENT SHALL BE COMPLETELY SCREENED FROM VIEW BY THE BUILDING PARAPET
- PREFABRICATED CURBS FOR ROOF TOP EQUIPMENT SHALL BE DESIGNED AND INSTALLED WITH TOP OR CURB LEVEL
   NO PLUMBING VENTS/EXHAUST UNITS WITHIN 10'-0" OF INTAKE
- OR 5'-0" OF EXTERIOR WALL N. ALL ROOF PENETRATIONS, INCLUDING PLUMBING AND ELECTRICAL ROOF JACKS SHALL BE 18" MINIMUM APART AND
- MADE PRIOR TO MEMBRANE ROOF INSTALLATION -SEE DETAILS 2 AND 3/A1.2 FOR MORE INFORMATION
- O. OVERFLOW SCUPPER RIMS SHALL BE 2" ABOVE PRIMARY ROOF DRAIN RIMS - COORDINATE AND VERIFY INSTALLATION
   P. PROVIDE CRICKET ON HIGH SIDE OF ALL MECHANICAL
- EQUIPMENT AND ROOF CURBS
- Q. EXTEND ROOFING COATING ON BACK SIDE OF PARAPET TO TERMINATE OR OVER WOOD PARAPET - SHOULD NOT BE SEEN ON EXTERIOR FACE OF BUILDING
- R. CONTRACTOR SHALL PAINT FRONT, TOP, BACK SIDES OF ALL WALL COPINGS

## KEYNOTES (#)

- 60 MIL. WHITE TPO OVER R-30 RIGID INSULATION ON 19/32" THICK PLYWOOD OVER PREFABRICATED TRUSSES @ 24" O.C. - TPO ROOFING FIRE CLASSIFICATION A, SEE SPECIFICATIONS SHEETS A9.0 - A9.5
- 2. METAL GUTTER SEE MECHANICAL DRAWINGS
- ROOF DRAIN AND OVERFLOW SEE DETAIL 4/A8.0
   ROOF HATCH AND GUARD RAILS, GUARD RAILS SHALL NOT EXTEND ABOVE THE LOWEST PARAPET ELEVATION OF 23'-8". - REFER TO DETAIL 6/A8.0
- PARAPET CAP FLASHING SEE SECTIONS AND DETAIL 11/A8.0
   NOT USED
   NOT USED
- J-BOX FOR PROPOSED SIGNAGE LOCATION REFER TO ELECTRICAL
   ROOF TOP UNIT ON CURB REFER TO MECHANICAL DWGS & 12/A8.0
- STEEL DECKING CANOPY SEE SHEET 3.1 & STRUCTURAL DRAWINGS
   FIRESTONE BUILDING PRODUCTS, X-TRED WALKWAY PAD OR
- FIRESTONE BUILDING PRODUCTS, X-TRED WALKWAY PAD OR EQUAL, PADS AROUND MECHANICAL UNITS - PATH FROM ROOF ACCESS HATCH
   ROOF MOUNTED EXHAUST FAN - SEE MECHANICAL DRAWINGS
- ROOF MOUNTED EXHAUST FAN SEE MECHANICAL DRAWINGS
   COLUMN BELOW, SHOWN FOR CLARITY
   DASHED LINE INDICATES SOFFIT BELOW
- 13. DASHED LINE INDICATES SOFFIT BELOW 14. HATCH INDICATES AREA OF ANGLED BRACING. RE: STRUCTURAL 15. TIE ROD, REFER TO A4.0 FOR FINISH & 7/A8.0 FOR DETAIL















